

INTRODUCING THE ENERGY SOLUTIONS PROGRAM



ES&P
ENERGY SOLUTIONS PROGRAM

HARRIS Integrated Solutions



BILLY BLACKBURN, ACEM

STRATEGIC BUSINESS DEVELOPMENT
MANAGER

843.655.2390

BILLYBLACKBURN@HARRISISI.COM

(COASTAL SC)

Billy Blackburn is the Business Development and Account Manager at Harris Integrated Solutions.

- 30 years veteran in the HVAC and DDC control industries*
- An Accredited Commercial Energy Manager (ACEM)*
- A former factory-certified centrifugal chiller technician and manager*

Billy holds certifications

- Allen Bradley PLC*
- Network Plus and CCNA training*
- Factory certified DDC control Technician*
- Former ALC/HIS Trainer and Training Manager*
- A regular contributor to *GroundBreak Carolina*.*



Integrated Solutions



TONY HOLCOMB, ACEM

ENERGY SOLUTIONS CONSULTANT
843.344.6899

TONYHOLCOMB@HARRISISI.COM

(COASTAL SC)

Tony Holcomb is an Energy Consultant with Harris Integrated Solutions

- *Retired Director of Maintenance and Operations for the Georgetown County School District.*
- *Served three years as Vice Chairman of the Association of South Carolina Energy Managers.*
- *An Accredited Commercial Energy Manager (ACEM)*
- *Named South Carolina Energy Manager of the Year in 2016 and received the South Carolina Energy Project of the Year award in 2013.*
- *Board member and HVAC advisor HGTC*
- *A regular contributor to *GroundBreak Carolina*.*




What is ESP?

The Energy
Solutions Program
(ESP) is a 3-tier
strategy

OUR GOAL is...

Reduce Energy
Use and Maintain
Building Comfort



1

What is the Energy Solutions Program?

Technology

The Building Automated System


Technology



Flexibility Energy Optimization
Ease of use

- Real-time data access
- Scheduling Platform
- Demand Response
- Setpoints Optimization
- Automated and Promptly






2

What is the Energy Solutions Program?

Tracking



Tracking



- Track and Benchmark Energy Usage
- Make informed decisions to reduce your energy costs.

Tracking




ENERGY STAR® Energy Performance Scorecard

82
out of 100

McLeod Health (Seacoast)

For Year Ending	July 31, 2024
Property Address	4000 Hwy 9 East Little River, South Carolina 29566
Primary Function	Hospital (General Medical & Surgical)
Gross Floor Area (ft ²)	325,060
Year built	1991
Energy Use per sq. ft.*	153.5 kBtu




What is the ENERGY STAR Score?

The ENERGY STAR score rates commercial building's energy performance relative to similar buildings nationwide. Expressed as a number on a simple 1-100 scale, the score rates performance on a percentile basis: a building with a score of 50 performs better than 50% of its peers. Higher scores mean better energy efficiency, resulting in less energy use and fewer greenhouse gas emissions. If a 1-100 score for a specific building type has not been developed, Site Energy Use Intensity (EUI) will be displayed on this scorecard.

Learn more at:

energystar.gov/scorecard

*Site energy use



What is the Energy Solutions Program?

3

Communication

HIS
ENERGYIQ
REPORTS

Communication

Winner of the 2013 South Carolina Energy Project of the Year



Identify areas of:

- Inefficiency
- Conserve energy & Save Money
- Provides proof of ECM's savings
- Kiosks and Websites
- To inform and educate about energy performance

What is



SMART ROOM AGENDA

- What is ESP *Smart Room*?
- The *Smart Room Beta* Test Results
- Power **Consumption** Reduction
- ROI





Smart Room: Utilizing Algorithms
across **Various Features**

- Motion **Detection**
- **Maintenance** Tracking
- **Fault** Detection
- Unit **Efficiency**

Georgetown County School District Beta Site One



ESP
ENERGY SOLUTIONS PROGRAM
SMART ROOM



HARRIS

Integrated Solutions



76.2 °F
00 %RH

97 kW


Module Status

Electric Heat S/S Off
Supply Fan S/S On
Dehumidification S/S Off
Mode cooling Reversing Valve On



Zone Temp 77.1 °F
Effective Cool Setpt 73.0 °F
Effective Heat Setpt 65.0 °F
Setpt Adj, by -3.0 °F
Zone Humidity 75.0 % RH
Humidity Setpt 60.0 % RH
Schedule State Occupied
until 2:30 PM on 9/30/2024

NOTES:





Optimum Start

Smart Room begins 1 hours transitioning from unoccupied to occupied temperatures

91.5 °F
00 %RH



108 kW

Zone Temp 73.5 °F
Supply Air 55.9 °F

Cooling Delta T 17.60 °F

HVAC Performance Capacity Chart

██████████	< Best	██████████	< Best
██████████	< Average	██████████	< Average
██████████	< Poor	██████████	< Poor

HEAT Degree Rise 5.06 °F per Hr
COOL Degree Rise 5.18 °F per Hr

Maintenance Hours

Component	Run Hours	PM Hours	Next PM	Alarm	Reset
Filter	22	100	78	Off	Green
Belt	22	325	303	Off	Green
Indoor Coil	22	650	628	Off	Green
Compressor	14	650	636	Off	Green

Set PM Hours according to manufacturer's recommendations

Unit Alarms

Zone Sensor Communication	Normal	Green
Zone Sensor Temp Reading	Normal	Green
Low Capacity	Normal	Green
Discharge Air Out of Range	Normal	Green
Zone RH Too High	Normal	Green
Zone RH Too Low	Normal	Green
Zone Humidity Sensor Reading	Normal	Green
Ion Generator	Normal	Green


Thermographic




Zone Temperature



Zone Humidity










Supply Fan



Compressor



Dehumidification






Optimum Start

Smart Room begins 4 hours ■■■■
 transitioning from unoccupied to occupied temperatures

76.1 °F
 00 %RH


97 kW

Zone Temp 77.1 °F
 Supply Air 73.0 °F



Cooling Delta T 4.10 °F


HVAC Performance Capacity Chart




Thermographic



Zone Temperature




Zone Humidity




Supply Fan



Color Trend




Zone Temp




Zone Relative Humidity



Sup Fan S/S




Compress 1 S/S



Compressor



Dehumidification



Dehumid S/S



Maintenance Hours

Component	Run Hours	PM Hours	Next PM	Alarm	Reset
Filter	14	500	486	Off ■	
Belt	14	200	186	Off ■	
Indoor Coil	14	500	486	Off ■	
Compressor	14	500	486	Off ■	

Set PM Hours according to manufacturer's recommendations

Unit Alarms

Zone Sensor Communication	Normal ■
Zone Sensor Temp Reading	Alarm ■
Low Capacity	Alarm ■
Discharge Air Out of Range	Alarm ■
Zone RH Too High	Normal ■
Zone RH Too Low	Normal ■
Zone Humidity Sensor Reading	Normal ■



Sep 27 2024 9:13:51.660 AM
Compress 1 S/S : On

Sep 27 2024 8:49:03.030 PM
Compress 1 S/S : Off



THE RESULTS

- First beta test was 12 units
- Found 23 ongoing issues first week
- Were able to identify energy saving and system issues.

1. **RTU-2 RM301:** Dehumidification is disabled, extended compressor operation.
2. **RTU-C14 RM44:** Low Env Index, Filter alarm, Discharge Air sensor failure.
3. **RTU-5 RM305 (Media Center):** Dehumidification is disabled, compressor has operated in 24 hours.
4. **RTU-C4 (Media Center):** Compressor operation for 11 hours; dehumidification is disabled.
5. **RTU-10:** Dehumidification is disabled; ion generator alarm.
6. **RTU-13:** Requires preventive maintenance for air filter; experiencing poor Delta T; dehumidification is disabled.



Beta Rooms





ASHRAE 36 Unoccupied Mode Strategies

1. Temperature Setback – When the space is unoccupied, heating and cooling setpoints are adjusted to reduce energy use

2. Ventilation Reduction – Outdoor air ventilation is minimized or shut off to prevent unnecessary conditioning of outside air.

3. Fan Operation – Fans are typically off unless required for setback temperature control or pressure maintenance.



4. Humidity Control – If necessary, humidity control may activate to prevent excessive moisture accumulation or dryness.

5. Reactivation Before Occupancy – Systems start before scheduled occupancy to ensure comfortable conditions when occupants arrive.



Normal School Week

WMHP-A4 RM131 - Motion Comparison



Savings per Sensor

Normal School Week

Normal School Week (2/3-2/7)

Room 131

Room 133

kW

Hours

kWh

kW

Hours

Supply Fan

1.2

2.75

3.3

1.2

16

19.2

Compressor

4

2.75

11

4

11

44

Electric Heat Strips

9

1

9

9

1

9

Total
kWh

23.3

Total kWh

72.2

Cost/kWh

\$0.18

Cost/kWh

\$0.18

Total Cost

\$4.19

Total Cost

\$13.00

Week

Year

SAVINGS

\$8.80


\$396.09

(based on 42 full weeks)



Holiday School

WMHP-A4 RM131 - Motion Comparison



Savings per Sensor

Holiday School Week

Holiday Week (2/17-2/21)

	Room 131			Room 133		
	kW	Hours	kWh	kW	Hours	
Supply Fan	1.2	1.5	1.8	1.2	36.25	43.5
Compressor	4	1.5	6	4	36.25	145
Electric Heat Strips	9	0.25	2.25	9	2	18
		Total kWh	10.05		Total kWh	206.5
		Cost/kWh	\$0.18		Cost/kWh	\$0.18
		Total Cost	\$1.81		Total Cost	\$37.17

SAVINGS **Week** **\$35.36** **Year** **\$247.53**

(Based on 7 holiday weeks)



Brown's Ferry Total Savings Total Savings

Rooms Normal Holiday Savings

27

\$10,694.43

\$6,683.31

\$17,377.74

**2023-24 Cost
Reduction**

**\$60,576.79
28.68%**



McLeod Health Seacoast Campus





Occupancy Indicator

Occupancy Optimization

- Medical rounds happen **every 45 minutes**
- When no motion is detected for 2 hours, setpoints move to the **unoccupied setting**.
- Countdown will begin 2 hours after the **last motion is detected**.
- Shows **occupancy status** on graphics page
- Can be **manually overridden** from graphic page
- **Does not interfere** with hospital operations or patient care.

BETA TEST RESULTS ROOM 101 & 102


THE RESULTS

- Both rooms are same size
- Same air handler supply air to both rooms
- Both VAV's has 3 banks of 3 KW of electric heat strip




Room 101 V1 VAV-3 - Heat Strip Comp

Room 101 V1 VAV-3 / Heating 1 S/S Room 101 V1 VAV-3 / Heating 2 S/S Room 101 V1 VAV-3 / Heating 3 S/S Notes



Room 102 V1 VAV-4 / Heating 1 S/S Room 102 V1 VAV-4 / Heating 2 S/S Room 102 V1 VAV-4 / Heating 3 S/S Notes





78.0 ° F
36.9 % RH

Room 101 V1 VAV-3

To: Bed Tower 1st Floor Pods A and D
RTU-1 Pods A & D

Module Status

Actual 275 CFM
Setpt 270 CFM
Damper 57 % Open

Supply Air
Temp
58.8 F°

AHU Status
Supply Air Temp 57.8 F°
Supply Air Static Actual 1.3 in. H2O



Electric Heat
Stage 1 Off
Stage 2 Off
Stage 3 Off



Zone Temp 67.8 ° F
Effective Cool Setpt 72.0 ° F
Effective Heat Setpt 67.0 ° F
Setpoint Adj. by -3.0 ° F
Scheduling Mode 24/7

Occupancy Indicator

ESP SMART ROOM



OCCUPIED

Will unoccupy in 118:17:00 Mins/Seconds

Smart Room Mode


Activated



Sensor Bypass


runs 24/7


Occupied Mode



NOTES:

Environmental Index 100.0 %



 75.8 ° F
42.3 % RH

Room 102 V1 VAV-4

To: Bed Tower 1st Floor Pods A and D
RTU-1 Pods A & D

Module Status

Actual 41 CFM
Setpt 0 CFM
Damper 0 % Open

Supply Air
Temp
73.0 F°

AHU Status
Supply Air Temp 57.4 F°
Supply Air Static Actual 1.3 in. H2O



Electric Heat
Stage 1 Off
Stage 2 Off
Stage 3 Off




Zone Temp 72.2 ° F
Effective Cool Setpt 78.0 ° F
Effective Heat Setpt 60.0 ° F
Setpoint Adj. by 0.0 ° F
Scheduling Mode 24/7

ESP
ENERGY SOLUTIONS PROGRAM
SMART ROOM

Smart Room Mode

Activated




Will unoccupy in 0:00 Mins/Seconds

Occupied Mode




NOTES:




runs  24/7

Environmental Index 0.0 %



ROOM 102 (NORMAL ROOM)




DAY	HEAT 1 HOUR	HEAT 2 HOURS	HEAT 3 HOURS
MONDAY	6.11	6.11	6.11
TUESDAY	5.9	5.9	5.9
WEDNESDAY	5.5	5.5	5.5
THURSDAY	8.3	8.3	8.3
FRIDAY	5.5	5.5	5.5
SATURDAY	15.9	15.9	15.9
SUNDAY	3.2	3.2	3.2
TOTAL	50.41	50.41	50.41

Hours of Operation Per Week: 151.23 Hours

Kilowatt Hours: 453.69 kwh / Cost \$36.30 Per Week

ROOM 101 (SMART ROOM)




DAY	HEAT 1 HOUR	HEAT 2 HOURS	HEAT 3 HOURS
MONDAY	0.0	0.0	0.0
TUESDAY	2.1	2.1	0.0
WEDNESDAY	3.0	3.0	0.0
THURSDAY	0.4	0.4	0.0
FRIDAY	3.2	3.2	0.4
SATURDAY	0.0	0.0	0.0
SUNDAY	0.0	0.0	0.0
TOTAL	8.7	8.7	0.4

Hours of Operation Per Week: 17.8 Hours


Kilowatt Hours: 53.4 kwh / Cost \$4.27 Per Week

SMART ROOM SUMMARY

- Annual **savings \$1,665.21** (per unit)
- Savings for **one wing (34 Rooms) \$56,617.14** (annually)
- ROI was **under 6-Months** (E-Heat)



ADDITIONAL SAVINGS





63.8 °F
47.2 %RH



= Occupied



= Unoccupied

Room 101 V1 VAV-3

Unoccupied

Room 102 V1 VAV-4

Unoccupied

Room 103 V1 VAV-5

Occupied

ROOM 104 V1 VAV-6

Occupied

Room 105 V1 VAV-8

Occupied

Room 106 V1 VAV-9

Occupied

ROOM 107 V1 VAV-10

Unoccupied

Room 108 V1 VAV-11

Occupied

ROOM 109 V2 CAV-1

Unoccupied

ROOM 110 V2 VAV-3

Occupied

Room 111 V2 VAV-4

Occupied

Room 112 V2 VAV-5

Occupied

ROOM 113 V2 VAV-7

Occupied

Room 114 V2 VAV-8

Occupied

Room 115 V2 VAV-9

Occupied

Room 116 V2 CAV-10

Unoccupied

B/C Pod Waiting Area V2 VAV-11

Occupied

1 PCU V2 VAV12

Occupied

2 PCU V2 VAV-13

Occupied

3 PCU V2 VAV-14

Occupied

4 PCU V2 VAV-15

Occupied

5 PCU V2 VAV-21

Occupied

6 PCU V2 VAV-20

Occupied

7 PCU V2 VAV-19

Occupied

8 PCU V2 CAV-18

Occupied

Room 117 V1 VAV-19

Occupied

Room 118 V1 VAV-20

Unoccupied

Room 119 V1 VAV-21

Occupied

Room 120 V1 VAV-22

Occupied

Anesthesia Office V1 VAV-26

Occupied

Anesthesia work room V1 VAV-25

Unoccupied

Orth. Pos. Supply V1 VAV-24

Occupied

Room 132 V1 VAV-23

Unoccupied

Break Room V1 VAV-12

Occupied





BILLY BLACKBURN, ACEM

STRATEGIC BUSINESS DEVELOPMENT
MANAGER

843.655.2390

BILLYBLACKBURN@HARRISISI.COM

(COASTAL SC)



TONY HOLCOMB, ACEM

ENERGY SOLUTIONS CONSULTANT

843.344.6899

TONYHOLCOMB@HARRISISI.COM

(COASTAL SC)



Any Questions



Integrated Solutions